

SIDEWALK REIMBURSEMENT VOUCHER

Date: _____

Name: _____

Address: _____

All bills must be certified with the Village Clerk before the hour for regular meeting of trustees

Trustee, (Sidewalk Committee) _____

The within bill audited at \$ _____ and ordered paid out of the following funds

Filed (date) _____ 20 _____

Village Clerk _____

The undersigned certifies that the items for services and disbursements mentioned in the within account, by him presented, are in all respects correct. That such disbursements and services have in fact been rendered, and that no part thereof has been paid or satisfied.

(Signature)

Sidewalk to be repaired must first be inspected and approved by Trustee on sidewalk committee. Call office 923-3791 for name and # of standing committee member.

**BEFORE ANY SIDEWALK WORK HAS BEEN STARTED.
PLEASE CALL THE MAIN OFFICE AT 315-923-3971 X201**

CHAPTER 44

ARTICLE II - SIDEWALKS

§44.25 Concrete Sidewalks for use by the general public

Sidewalks hereinafter constructed or replaced on public and/or private property in the Village of Clyde shall be constructed according to the specifications hereinafter set forth so as to establish reasonable safeguards for the safety, health and welfare of the general public by the requirement that all sidewalks available for use of the general public in the Village of Clyde be of uniform size and construction.

A. Subgrade: Walks shall be a minimum of four (4) feet in width and four inches (4") in thickness. The area on which the walk is to be constructed shall be excavated and filled to an elevation to be established by the Village of Clyde. The said area, called subgrade, shall be shaped to a plane surface, parallel to and four inches (4") below the surface of the finished grade of the walk, as established, and shall extend six inches (6") on either side of the walk in excavation and eighteen inches (18") on either side in embankment.

The subgrade shall slope one quarter inch (1/4") per foot horizontally toward the roadway and follow the longitudinal grade established.

The subgrade material shall be free of large stones, tree roots or any other foreign substance and it shall be thoroughly compacted.

The subgrade shall be wetted prior to the placement of the concrete.

Where tree roots are encountered, then six inches (6") below the bottom of the walk shall be excavated and all roots in this six inch (6") depth removed. The area shall be backfilled with gravel, or other material free of topsoil, and compacted before laying walks.

B. Forms:

Forms shall be free from warp and have sufficient strength to resist springing out of shape. The forms shall be well staked or otherwise held to the established lines and the upper edges shall conform to the established grade of the walk. All wood forms shall be thoroughly wetted and all steel forms shall be oiled before any concrete is deposited against them. All mortar, dirt or other extraneous material will be removed from forms before they are used.

C. Concrete:

All concrete placed in walks shall be Class "A" concrete having a minimum 28-day compressive strength of 3500 psi. A minimum of six (6) bags of cement shall be placed in each cubic yard of concrete. The cement used shall be Type II Portland Cement. The concrete, when placed, shall have a slump not exceeding three (3") inches.

The concrete aggregate shall be crushed stone or crushed gravel having a minimum of eighty-five percent (85%) of fractured particles.

The coarse aggregate shall consist of No. 1 stone and No. 2 stone with the mixture containing fifty percent (50%) of each.

The concrete shall be placed in one course to the full depth of four inches (4").

D. Joints and Surface Finish:

The concrete surface shall be scored at intervals of four feet (4') or as otherwise required by the Village of Clyde so that the finished walk will be marked in squares. The concrete shall be finished to produce a smooth and uniform surface.

Transverse construction joints shall extend to the full depth of the slab and spaced 20 to 24 feet apart. The edges of each joints shall be finished with an edging tool having a 1/4 inch radius.

A premoulded bituminous joint filler shall be installed at all joints between sidewalk and curb, pavement, building, existing sidewalk, driveways and aprons.

The surface shall be sealed and edged by magnesium troweling, and lightly broomed with care being taken to eliminate the markings left by the edging tool.

E. Curing:

The concrete shall be cured by covering it with a sisalkraft paper or burlap which shall be wetted and kept in place for seven (7) days. As an alter-

nate, the use of a colorless curing compound product will be accepted when sprayed as per manufacturer's instructions.

F. Measurement:

The quantity of concrete sidewalk to be subsidized will be the number of square feet of walk laid to these specifications.

G. Reimbursement:

That upon substantial compliance with provisions "A" through "F" of this ordinance, the owner of said property upon which the sidewalk has been constructed, shall be entitled to reimbursement at the rate of \$5.00 per *linear* foot of said sidewalk so improved.

That the Village of Clyde Board of Trustees or any person designated by them, shall have the discretion to determine whether or not there has been substantial compliance with provisions "A" through "F" of this ordinance.

That the Village of Clyde Board of Trustees shall also have the discretion to compensate for the improvement of any sidewalk at a rate greater than or less than \$5.00 per *linear* foot.